

**IOWA DEPARTMENT OF NATURAL RESOURCES
NPDS REPORTING SYSTEM - DISCHARGE MONITORING REPORT
FACILITY INFORMATION**

This form is valid 4/1/2015 to 3/31/2020

Facility Name: SIOUX CITY, CITY OF STP

Permit #: 9778001

Month/Year:

11	2017
----	------

Outfall #(s): 001 - DISCHARGE FROM AN ACTIVATED SLUDGE WASTEWATER TREATMENT PLANT.

Operator Name:

Jim Maynes & Mark Simms

Certification #:

6232 and 5129

Phone #:

712.279.6113

Lab Cert. #:


--

323

Comments:

Jim Maynes operator-in-charge until 11/9/17. Seaboard Triumph Foods obtained approximately 5,000 gal of digested sludge to use as "seed" sludge in their anaerobic lagoons on 11-20-17. Effl TSS exceeded max 7-day ave. Reported via email & phone to FO3. Wasting adjustment made. TRC measured on 11/28/17 for engineering study. Raw BOD 11/17/17 ave result 1095 mg/L, too strong for series so value not reported *Include Comments longer than 1000 characters in email

Signature:

 5129 12-15-2017

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for known violations.
